



# Variable Frequency AC Resonant Test Systems for On-Site GIS Testing



- Lightweight, transportable, easy to set-up
- HV section power to weight ratio up to 4 times, compared to conventional fixed-frequency RTS
- Pure sinusoidal output voltage
- Complies with IEC 60517, IEC 62271-203, and IEC's frequency range of 45 to 300 Hz
- Virtually maintenance free, no movable internal parts




## APPLICATION

Variable Frequency Resonant Test Systems are generally used where a lightweight, transportable unit is a requirement. Primary application is GIS / GIL testing. Other test objects which are capacitive in nature such as cables, generators, and motors may also be tested. Non-mobile systems for factory or laboratory use are also available.

## THEORY OF OPERATION

A Variable Frequency Resonant Test System takes advantage of resonance theory. To achieve resonance, the capacitive reactance (test object) has to equal the inductive reactance (high voltage reactor). In a Variable Frequency Resonance System, the reactor is non-variable; therefore, the frequency of the circuit is adjusted until resonance is achieved. This adjustment of the resonant circuit is commonly referred to as "tuning". Once resonance has been achieved only the resistive (real) losses in the circuit have to be supplied. The output voltage and the incoming power drawn from the mains is a function of the "Q" or quality factor of the circuit. The higher the system Q, the lower the incoming power requirement.



## CYLINDER TYPE REACTORS

Phenix Technologies' reactors are constructed of an FRP (Fiberglass Reinforced Polymer) cylinder enclosing oil insulated reactor coils. One of the main features of cylinder type reactors is the capability to stack multiple reactors. When multiple reactors are connected in series (cascading), very high voltages can be achieved. The unique reactor coil design is manufactured of radially laminated magnetic cores enclosed by copper windings. The use of high quality materials results in a low loss, high Q reactor. This design provides a lightweight and transportable test system. Cylinder type reactors operate in series resonance mode.



## ELECTRONIC POWER REGULATOR

At the heart of the system is a specially designed electronic regulator that converts the mains service into a variable voltage, variable frequency power source that is ideally suited for use with a Variable Frequency Resonant Test System. The excellent resolution and frequency stability maintain a reliable, controllable resonant test circuit.

## HIGH ACCURACY MEASUREMENT SYSTEM

A high precision measuring system is designed to enable accurate measurements of voltages and currents. The metered information is displayed on the Human Machine Interface (HMI). The values displayed on the HMI are performed as a function of the Programmable Logic Controller (PLC).

Our systems function in compliance with IEC 60060, IEEE 4, and other recognized national and international industry testing standards.

Calibration Certificate traceable to NIST (National Institute of Standards and Technology, USA) is issued with every system. ISO17015 traceable voltmeter calibration is available as an option upon request.

## HIGH VOLTAGE PROTECTION

High voltage protection or dampening impedances are supplied to provide protection to the system when a test object breakdown or flashover occurs. Fast transients are blocked and shunted to ground without causing damage to the high voltage components.







## DESIGNED FOR TRANSPORTATION AND ON-SITE TESTING

Testing of substation GIS / GIL requires a system that is easily ported and packaged for frequent movement. Transport covers, sturdy shipping boxes, and frames for all components of the Variable Frequency Resonant Test System can be supplied by Phenix Technologies.



Step	Voltage	Current	PO	Gas %	Dwell	Duration
0	0 kV	0 A				00:00:00
1	40 kV	0.3 A			27.8 00:00:15	00:00:03
2	40 kV	0.3 A				00:00:15
3	50 kV	0.36 A			27.7 00:00:15	00:00:28
4	60.5 kV	0.38 A				00:00:43
5	69 kV	0.43 A			27.7 00:00:15	00:00:00
6	69.3 kV	0.43 A				00:01:00
7	79 kV	0.49 A			27.7 00:00:15	00:01:11
8	88 kV	0.5 A				00:01:26
9	89 kV	0.55 A			27.5 00:00:10	00:01:38

## CONTROLS

Phenix Technologies uses the latest development in computer-assisted controls. Our configuration creates ease in set-up and simplicity in testing.

The test system features a

full-color, liquid crystal display and

Ethernet port to select automation modes through

a remote personal computer interface. The controls allow the operator to easily perform repeatable testing. All test data is

collected by the data acquisition software and stored for later recall or test report generation.



Recipe ID: [Step] Description: [A step test]

Step Test

Start Voltage (kV): [50] Hr: [ ] Hr: [ ]

Step Voltage (kV): [10] Min: [ ] Min: [ ]

Last Step: [5] Sec: [15] Sec: [10]

Ramp Rate: [20] %

[Save] [Cancel]



Heaviest  
Component  
of VF RTS

Model Number	Maximum Test Voltage kV	Current A	Frequency Range Hz	# of Modules in Series	Duty Cycle	HV Module Weight lbs/kg	*Load Capacitance Range nF	HV Section Height ft/m
VRTS8CC200-900-S	200	4.5	[45]..60-300	1	1 Hr ON / 23 Hr OFF	1750 / 795	[106] 2.3-59	7 / 2.1
VRTS8CC200-900-L	200	4.5	[45]..60-300	1	1 Hr ON / 4 Hr OFF	3200 / 1450	[106] 2.3-59	9 / 2.6
VRTS8CC250-750	250	3.0	[45]..60-300	1	1/2 Hr ON / 6 Hr OFF	1780 / 807	[56] 1.3-31	7 / 2.1
VRTS8CC400-1800-2S	400	4.5	[45]..60-300	2	1 Hr ON / 23 Hr OFF	1750 / 795	[53] 1.1-29	11 / 3.2
VRTS8CC400-1800-2L	400	4.5	[45]..60-300	2	1 Hr ON / 4 Hr OFF	3200 / 1450	[53] 1.1-29	14 / 4.2
VRTS8CC500-1500-2	500	3.0	[45]..60-300	2	1/2 Hr ON / 6 Hr OFF	1780 / 807	[28] 0.7-15	12 / 3.7
VRTS8CC600-2700-3S	600	4.5	[45]..60-300	3	1 Hr ON / 23 Hr OFF	1750 / 795	[35] 0.8-20	14 / 4.3
VRTS8CC600-2700-3L	600	4.5	[45]..60-300	3	1 Hr ON / 4 Hr OFF	3200 / 1450	[35] 0.8-20	22 / 6.7
VRTS8CC750-2250-3	750	3.0	[45]..60-300	3	1/2 Hr ON / 6 Hr OFF	1780 / 807	[18] 0.4-10	17 / 5.1
VRTS8CC800-3600-4S	800	4.5	[45]..60-300	4	1 Hr ON / 23 Hr OFF	1750 / 795	[26] 0.6-14	23 / 6.9
VRTS8CC800-3600-4L	800	4.5	[45]..60-300	4	1 Hr ON / 4 Hr OFF	3200 / 1450	[26] 0.6-14	27 / 8.2
VRTS8CC1000-3000-4	1000	3.0	[45]..60-300	4	1/2 Hr ON / 6 Hr OFF	1780 / 807	[14] 0.3-8	30 / 8.9

\*Load Capacitance Range indicated is at maximum output voltage and Load Capacitance shown in brackets [ ] indicates frequency/reduced voltage operation.

## OPERATOR TRAINING/WORLDWIDE SERVICE AND SUPPORT

Commissioning and training is available to provide your operator with the information and resources they need for efficient and safe use of the test system. Long-term customer support is provided from our fully experienced and knowledgeable staff. Future periodic calibration of the metering is easily accomplished by one of our PHENIX service technicians keeping your system at top performance for many years.

High Voltage • High Current • High Power Test Systems and Components

ISO 9001  
CERTIFIED



www.phenixtech.com

**World Headquarters**  
Phenix Technologies, Inc.  
75 Speicher Drive  
Accident, MD 21520 USA  
Ph: +1.301.746.8118  
Fx: +1.301.895.5570  
Info@phenixtech.com

### Branch Offices

**Phenix Systems AG**  
Riehenstrasse 62A, 4058 Basel, Switzerland  
Ph: +41.61.383.2770 • Fx: +41.61.383.2771  
Info@phenixsystems.com

**Phenix Asia**  
Zhong Cheng Rd, Sec 1, No 177, 2F, Taipei 11148 Taiwan  
Ph: +886.2.2835.9738 • Fx: +886.2.2835.9879  
Info@phenixasia.com

